



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Paul R. LePage  
GOVERNOR

David Bernhardt  
COMMISSIONER

May 12, 2011  
Subject: **Dixmont, Newport & Plymouth**  
Federal Project No: STP-1279(000)X &  
STP-1799(200)X  
State PINs: 012790.00 & 017992.00  
**Amendment No. 2**

Dear Sir/Ms:

The following questions have been received:

**Question:** Can the option 3 pipes be HDPE instead of RCP?

**Response:** No

**Question:** Will the existing drainage at Sta. 3+00 and 6+50 be abandoned in place or removed?

**Response:** Abandoned in place.

Consider this information prior to submitting your bid on May 18, 2011.

Sincerely,

For  
Scott Bickford  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER